


La Verne Fire Department

Designation of Fire Lanes

Fire Department access and/or fire lanes shall be identified on the approved site plan for new developments or on the approved building plans for tenant improvements or residential projects. The Fire Chief or Fire Marshal may determine the need for additional requirements, or may approve alternate methods of compliance with the following.

1. Fire Department access for fire lanes shall be identified on private streets or drives by use of the phrase "NO PARKING-FIRE LANE, CVC 22500.1" and shall be designated by the use of one or more of the following:
 - a. Approved SIGNS
 - b. Approved RED CURBS or
 - c. Approved ROADWAY STRIPING
 - d. Any combination of the above.

2. SIGNS:
 - a. Shall be twelve (12) inches in width by eighteen (18) inches in height.
 - b. Lettering shall be red on a white background, and no less than three (3) inches in height. The perimeter of the sign shall have a red border no more than one (1) inch in width.
 - c. Signs shall read as follows:



- d. Signs shall be installed so that there is no less than seven (7) feet clear from the bottom of the sign to finished grade. Temporary signs must be approved by the Fire Department prior to placement and use.

- e. The distance between signs shall not exceed fifty (50) feet and there shall be a sign within five (5) feet of the beginning and end of the FIRE LANE.
- f. Installation and maintenance of signs located on private streets and drives shall be the responsibility of the property owner.

3. RED CURBS:




- a. Curbing which is used in designating FIRE LANES shall be painted OSHA Safety Red, or equivalent.
- b. White lettering no less than three (3) inches in height shall be placed on top of the red curbing and shall read "NO PARKING-FIRE LANE CVC 22500.1".
- c. Such lettering shall be located a maximum of thirty-five (35) feet apart and within five (5) feet from the beginning and end of the designated FIRE LANE.
- d. Installation and maintenance of red curbing located on private streets and drives shall be the responsibility of the property owner.

4. ROADWAY STRIPING


- a. Areas designated to be a FIRE LANE where no curbs exist shall be striped.
- b. Striping shall consist of three (3) inch wide white stripes on a diagonal basis for the full width and length of the FIRE LANE.
- c. White lettering a minimum dimension of two (2) inches in width by twelve (12) inches in height, per letter, shall read "NO PARKING-FIRE LANE CVC 22500.1" and shall be painted within the striping.
- d. Such lettering shall be located a maximum of thirty-five (35) feet apart and within five (5) feet of the beginning and end of the FIRE LANE.
- e. Installation and maintenance of roadway striping located on private streets and drives shall be the responsibility of the property owner.

“NO PARKING – FIRE LANE” STANDARDS (diagrams not to scale)

FIRE LANE SIGNS:



("FIRE LANE NO PARKING" sign locations along sidewalk or building without sidewalk)



“NO PARKING – FIRE LANE” STANDARDS (diagrams not to scale) continued

RED CURBS (continued)

